



ADA COUNTY PROCUREMENT

200 West Front Street
Boise, Idaho 83702-7300

DATE: August 15, 2018
TO: All Plan Holders
FROM: Ada County Procurement
NO. OF PAGES: 1

Bid 18083 Expo Idaho Large Animal Barn Roof Replacement and Structural Repairs Project

BIDS DUE: August 20, 2018 by 4:00 p.m. local time
Ada County Procurement, 200 W. Front St., Rm. 2210, Boise, ID 83702

ADDENDUM NO. 3

NOTICE TO BIDDERS:

1. This addendum shall be considered part of the documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original documents, this addendum shall govern and take precedence.
2. Bidders are hereby notified that they shall make any necessary adjustment in their estimates on account of this addendum. It will be construed that each bid is submitted with full knowledge of all modifications and supplemental data specified herein.
3. **Bidders must acknowledge in their bids that all addenda have been received or the bid may be deemed non-responsive.**

Please See Attached:

- Clarification:
 - Plywood thickness regarding bidding purposes:
 - ¾" plywood for the 2 foot on center rafter (truss) span